



ADDENDUM #4

DATE: February 20, 2024

TO: Prospective Proposers

RE: Addendum #4
Fire Alarm and Monitoring Services
Tyler Junior College
RFP #24-08

NOTICE TO PROPOSERS:

This Addendum forms a part of the Request for Proposal. Acknowledge receipt of this Addendum in the space provided on the Vendor Verification Form. Failure to do so may subject Proposer to disqualification.

BID DATE EXTENSION: We have extended the due date. Proposals are due by Tuesday, April 9, 2024 @ 12:00 pm Central Daylight Time (CDT). Delivered-to information has not changed.

Additional Information

Fire alarm panels may be connected via fiber provided the vendor can provide documentation from the manufacturer of an acceptable attenuation db loss of .5db/km or greater. It is still not preferred and once they provide the minimum db loss, we have to test our fiber to confirm we can meet that requirement.

Fire alarm vendors should provide a proposal with voice speakers in resident halls only and a proposal with voice speakers in all buildings.

The project completion date for the awarded vendor will be August 31, 2026.

QUESTION #1: Will there be bonds required?

ANSWER: Yes, the awarded vendor will be asked to provide a payment and performance bond.

End
